

Outfall Inspection Summary

Outfall Name: Drain B

Receiving Waters: Logger Creek	Pipe Type: CMP Pipe Size: 36"	Lat: 43.58975 Long: -116.18095				
Date: 6/24/2024 Personnel: KC, EL	Comments: Outfall screened on the east side of E Parkway Dr. The presence of detergents exceeds benchmark values.					
Structural Condition	Good					
Sedimentation	None					
Staining	None					
Odor	None					
Vegetation	Typical					
Floatables (Not Trash)	None					
Trash Observed	None	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 25%;">Trash Rank</td> <td style="width: 25%; text-align: center;">--</td> <td style="width: 25%;">Trash Source</td> <td style="width: 25%; text-align: center;">--</td> </tr> </table>	Trash Rank	--	Trash Source	--
Trash Rank	--	Trash Source	--			
Flow	Yes	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 25%;">Amount</td> <td style="width: 25%; text-align: center;">Substantial</td> <td style="width: 25%;">Flow Rate(cfs)</td> <td style="width: 25%; text-align: center;">0.7743</td> </tr> </table>	Amount	Substantial	Flow Rate(cfs)	0.7743
Amount	Substantial	Flow Rate(cfs)	0.7743			

Results:

Temp (C)	DO (mg/L)	pH (S.U.)	Cond (uS/cm)	Chlorine	Copper	Phenols	Turbidity (NTU)
13.81	8.4	7.88	149.0	<0.1	<0.1	<0.1	1.85

E.Coli (MPN)	TSS (mg/L)	ORP (mg/L)	Total P (mg/L)	Detergents (mg/L)
193.5	3.20	0.0283	0.0328	0.01

Illicit Discharge?	Unlikely
---------------------------	----------

